






# AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

<b>Applicant:</b>	M/s.Thermax Limited.	<b>Manufacturer:</b>	Thermax (Zhejiang) Cooling & Heating Engineering Co., Ltd.
<b>Address:</b>	D-13, M.I.D.C Industrial Area, R.D.Aga Road,Chinchwad, Pune- 411019.	<b>Address:</b>	645, Chayuan Road, JIAXING Economic Development Zone, JIAXING, ZJHZ 314003
<b>Country:</b>	India	<b>Country:</b>	China
<b>Contact:</b>	Mr. J.J. Cohen	<b>Contact:</b>	Ravi Inamdar
<b>Phone:</b>	91-20-66122502	<b>Phone:</b>	86-573-83968777
<b>FAX:</b>	91-20-27475907	<b>FAX:</b>	86-573-83968771
<b>Email:</b>	jcohen@thermaxindia.com	<b>Email:</b>	ravi.inamdar@thermax-china.com
<b>Party Authorized To Apply Mark:</b>	Same as Manufacturer		
<b>Report Issuing Office:</b>	Intertek India		

**Control Number:** 4009034      **Authorized by:**  \_\_\_\_\_  
 Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Standard for Safety for Heating and Cooling Equipment (ANSI/UL 1995 and CAN/CSA C22.2 No.236-11, Fourth Edition, dated October 14, 2011)
<b>Product:</b>	Vapour Absorption Chiller
<b>Brand Name:</b>	Thermax.
<b>Models:</b>	Double Effect Steam Driven Chillers, 2B Series: 2B 2K C , 2B 2L C , 2B 2M C , 2B 2N C , 2B 3K C , 2B 3L C , 2B 3M C , 2B 4K C , 2B 4L C , 2B 4M C , 2B 5K C , 2B 5L C , 2B 5M C , 2B 5N C , 2B 6K C , 2B 6L C , 2B 7K C , 2B 7L C , 2B 7M C , 2B 8K C , 2B 8L C , 2B 8M C , 2B 8N C , 2B 9K C , 2B 9L C



# AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

<b>Applicant:</b>	M/S Thermax Limited	<b>Manufacturer:</b>	M/S Thermax Limited
<b>Address:</b>	D-13, M.I.D.C Industrial Area, R.D.Aga Road,Chinchwad, Pune- 411019.	<b>Address:</b>	D-13, M.I.D.C Industrial Area, R.D.Aga Road,Chinchwad, Pune- 411019.
<b>Country:</b>	India	<b>Country:</b>	India
<b>Contact:</b>	Mr. J.J. Cohen	<b>Contact:</b>	Mr. J.J. Cohen
<b>Phone:</b>	91-20-66122502	<b>Phone:</b>	91-20-66122502
<b>FAX:</b>	91-20-27475907	<b>FAX:</b>	91-20-27475907
<b>Email:</b>	jcohen@thermaxindia.com	<b>Email:</b>	jcohen@thermaxindia.com
<b>Party Authorized To Apply Mark:</b>	Same as Manufacturer		
<b>Report Issuing Office:</b>	Dallas, TX		

**Control Number:** 2003466      **Authorized by:** \_\_\_\_\_  
Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Standard for Safety Heating and Cooling Equipment, ANSI/ UL 1995 / CSA C22.2#236, issued 2011/10/14, 4th Ed. Standard for Safety Gas-Fired, Heat Activated Air Conditioning and Heat Pump Appliances, ANSI Z21.40.1/ CSA/CGA 2.91-M96, issued 1996/01/01, 1st Ed., Addenda A: 1997; Reaffirmed 2012
<b>Product:</b>	Double Effect Direct-Fired Absorption Chillers. Double Effect Exhaust and Direct-Fired Chillers.
<b>Brand Name:</b>	Thermax
<b>Models:</b>	GD, EDG series and 2V, 2DV series.



# AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

<b>Applicant:</b>	M/S Thermax Limited	<b>Manufacturer:</b>	Thermax (Zhejiang) Cooling and Heating Engg.Co.,Ltd
<b>Address:</b>	D-13, M.I.D.C Industrial Area, R.D.Aga Road,Chinchwad, Pune- 411019.	<b>Address:</b>	645 , Chayuan Road , Jiaxing Economic Development Zone , Jiaxing , Zhejiang
<b>Country:</b>	India	<b>Country:</b>	China
<b>Contact:</b>	Mr. J.J. Cohen	<b>Contact:</b>	Mr. Ravi Inamdar
<b>Phone:</b>	91-20-66122502	<b>Phone:</b>	+86 573 83968777
<b>FAX:</b>	91-20-27475907	<b>FAX:</b>	
<b>Email:</b>	jcohen@thermaxindia.com	<b>Email:</b>	ravi.inamdar@thermax-china.com
<b>Party Authorized To Apply Mark:</b>	Same as Manufacturer		
<b>Report Issuing Office:</b>	Dallas, TX		

**Control Number:** 4009034      **Authorized by:** \_\_\_\_\_  
Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Standard for Safety Heating and Cooling Equipment, ANSI/ UL 1995 / CSA C22.2#236, issued 2011/10/14, 4th Ed. Standard for Safety Gas-Fired, Heat Activated Air Conditioning and Heat Pump Appliances, ANSI Z21.40.1/ CSA/CGA 2.91-M96, issued 1996/01/01, 1st Ed., Addenda A: 1997; Reaffirmed 2012
<b>Product:</b>	Double Effect Direct-Fired Absorption Chillers. Double Effect Exhaust and Direct-Fired Chillers.
<b>Brand Name:</b>	Thermax
<b>Models:</b>	GD, EDG series and 2V, 2DV series.



# AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

**Applicant:** M/s.Thermax Limited.

**Manufacturer:** M/s.Thermax Limited.

**Address:** D-13, M.I.D.C Industrial Area, R.D.Aga Road,Chinchwad, Pune- 411019.

**Address:** D-13, M.I.D.C Industrial Area, R.D.Aga Road,Chinchwad, Pune- 411019.

**Country:** India.

**Country:** India.

**Contact:** Mr. J. J. Cohen

**Contact:** Mr. J. J. Cohen

**Phone:** 91-20-66122502

**Phone:** 91-20-66122502

**FAX:** 91-20-27475907

**FAX:** 91-20-27475907

**Email:** [jcohen@thermaxindia.com](mailto:jcohen@thermaxindia.com)

**Email:** [jcohen@thermaxindia.com](mailto:jcohen@thermaxindia.com)

**Party Authorized To Apply Mark:** Same as Manufacturer

**Report Issuing Office:** India

**Control Number:** 2003466

**Authorized by:** *Ready You for*  
William T. Starr, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
165 Main Street, Cortland, NY 13045  
Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699

<b>Standard(s):</b>	UL 1995-Fourth Edition, dated October 14, 2011- Standard for Safety for Heating and Cooling Equipment.
<b>Product:</b>	Hot Water and Steam Absorption Chillers.
<b>Brand Name:</b>	Thermax.



## AUTHORIZATION TO MARK

<b>Model:</b>	<p>Low Temperature(LT) Hot Water Chillers (5G series), Single Effect; <b>5GX<sub>1</sub>Y<sub>1</sub>C</b> series; where " X" can be any number from 1 to 10 and "Y" can be either alphabet: K, L , M or N.</p> <p>High Temperature(HT) Hot Water Chillers (2G series), Double Effect; <b>2GX<sub>1</sub>Y<sub>1</sub>C</b> series; where " X" can be any number from 1 to 9 and "Y" can be either alphabet: K, L , M or N.</p> <p>Steam Driven Chillers (2B series), Double Effect; <b>2BX<sub>1</sub>Y<sub>1</sub>C</b> series;where " X" can be any number from 1 to 9 and "Y" can be either alphabet: K, L , M or N.</p> <p><b>Models (5G Series):</b> 5G 1KC, 5G 1LC, 5G 1MC, 5G 2KC, 5G 2LC, 5G 2MC, 5G 2NC, 5G 3KC, 5G 3LC, 5G 3MC, 5G 4KC, 5G 4LC, 5G 4MC, 5G 5KC, 5G 5LC, 5G 6KC, 5G 6LC, 5G 6MC, 5G 6NC, 5G 7KC, 5G 7LC, 5G 8KC, 5G 8LC, 5G 8NC, 5G 9KC, 5G 9LC, 5G 10KC, 5G 10LC.</p> <p><b>Models (2G series):</b> 2G 1KC, 2G 1LC, 2G 1MC, 2G 2KC, 2G 2LC, 2G 2MC, 2G 2NC, 2G 3KC, 2G 3LC, 2G 3MC, 2G 4KC, 2G 4LC, 2G 4MC, 2G 5KC, 2G 5LC, 2G 6KC, 2G 6LC, 2G 6MC, 2G 6NC, 2G 7KC, 2G 7LC, 2G 8KC, 2G 8MC, 2G 8NC, 2G 9KC, 2G 9LC.</p> <p><b>Models (2B series):</b> 2B 1KC, 2B 1LC, 2B 1MC, 2B 2KC, 2B 2LC, 2B 2MC, 2B 2NC, 2B 3KC, 2B 3LC, 2B 3MC, 2B 4KC, 2B 4LC, 2B 4MC, 2B 5KC, 2B 5LC, 2B 6KC, 2B 6LC, 2B 6MC, 2B 6NC, 2B 7KC, 2B 7LC, 2B 8KC, 2B 8LC, 2B 8MC, 2B 8NC, 2B 9KC, 2B 9LC.</p>
---------------	--



# AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

<b>Applicant:</b>	M/s.Thermax Limited.	<b>Manufacturer:</b>	M/s.Thermax Limited.
<b>Address:</b>	D-13, M.I.D.C Industrial Area, R.D.Aga Road,Chinchwad, Pune- 411019.	<b>Address:</b>	D-13, M.I.D.C Industrial Area, R.D.Aga Road,Chinchwad, Pune- 411019.
<b>Country:</b>	India	<b>Country:</b>	India
<b>Contact:</b>	Mr. J.J. Cohen	<b>Contact:</b>	Mr. J.J. Cohen
<b>Phone:</b>	91-20-66122502	<b>Phone:</b>	91-20-66122502
<b>FAX:</b>	91-20-27475907	<b>FAX:</b>	91-20-27475907
<b>Email:</b>	jcohen@thermaxindia.com	<b>Email:</b>	jcohen@thermaxindia.com
<b>Party Authorized To Apply Mark:</b>	Same as Manufacturer		
<b>Report Issuing Office:</b>	Intertek India		

**Control Number:** 2003466      **Authorized by:** Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Standard for Safety for Heating and Cooling Equipment (ANSI/UL 1995 and CAN/CSA C22.2 No.236-11, Fourth Edition, dated October 14, 2011)
<b>Product:</b>	Vapour Absorption Chiller
<b>Brand Name:</b>	Thermax.

XX 10A TCU - S

XX – SD (Steam drive double effect machine)  
ED (Exhaust drive double effect machine)  
HD (Hot water drive double effect machine)

**Models:**

10A - 10= Number from 10, 20, 30, 40, 50, 60, 70, 80 and 90 (Represents Frame size and Capacity)

A = different options, can be A, B, C or D

TCU- T = Twin type design (T will be optional)

C = Chiller

U =Ultra Efficient Series

S- With Side Arm Heat Exchanger (optional)





# AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

<b>Applicant:</b> M/s.Thermax Limited.	<b>Manufacturer:</b> Thermax (Zhejiang) Cooling & Heating Engineering Co., Ltd.
<b>Address:</b> D-13, M.I.D.C Industrial Area, R.D.Aga Road,Chinchwad, Pune- 411019.	<b>Address:</b> 645, Chayuan Road, JIAXING Economic Development Zone, JIAXING, ZJHZ 314003
<b>Country:</b> India	<b>Country:</b> China
<b>Contact:</b> Mr. J.J. Cohen	<b>Contact:</b> Ravi Inamdar
<b>Phone:</b> 91-20-66122502	<b>Phone:</b> 86-573-83968777
<b>FAX:</b> 91-20-27475907	<b>FAX:</b> 86-573-83968771
<b>Email:</b> jcohen@thermaxindia.com	<b>Email:</b> ravi.inamdar@thermax-china.com
<b>Party Authorized To Apply Mark:</b> Same as Manufacturer	
<b>Report Issuing Office:</b> Intertek India	

**Control Number:** 4009034      **Authorized by:** \_\_\_\_\_  
Thomas J. Patterson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Standard for Safety for Heating and Cooling Equipment (ANSI/UL 1995 and CAN/CSA C22.2 No.236-11, Fourth Edition, dated October 14, 2011)
<b>Product:</b>	Vapour Absorption Chiller
<b>Brand Name:</b>	Thermax.

XX 10A TCU - S

XX – SD (Steam drive double effect machine)  
ED (Exhaust drive double effect machine)  
HD (Hot water drive double effect machine)

**Models:**

10A - 10= Number from 10, 20, 30, 40, 50, 60, 70, 80 and 90 (Represents Frame size and Capacity)

A = different options, can be A, B, C or D

TCU- T = Twin type design (T will be optional)

C = Chiller

U =Ultra Efficient Series

S- With Side Arm Heat Exchanger (optional)

